

eco-INSTITUT, Schanzenstr. 6-20, D-51063 Köln

Hilti Entwicklungsgesellschaft mbH
Mrs. Cintia Chagas de Oliveira
Hiltistraße 6
86916 Kaufering

Dear Mrs. Chagas de Oliveira,

based on the evaluation of Test Report No. 55111-A003 II dated 2020-06-26 the testing results of the product **Firestop Acrylic Sealant CFS-S ACR / CP 606** manufactured by **Hilti Entwicklungsgesellschaft mbH** comply with the requirements of

- VOC content ASTM D 2369 – 10 and South Coast Air Quality Management District (SCAQMD) Rule 1168

VOC content	VOC Limit Value*
63.26 g/L	420 g/L

* VOC Limit Value for "Other Sealants" (SCAQMD 1168, 01/2005)

Cologne, 2020-07-31



Marc-Anton Dobaj, M.Sc. Crystalline Materials
(Project manager)